

**IAPMO RESEARCH AND TESTING, INC.**

5001 E. Philadelphia Street, Ontario, CA 91761-2816  
 (909) 472-4100 • Fax (909) 472-4244 • www.iapmo.org

**LISTED PRODUCTS**

Effective Date :

May 2005

Void After: May 2006

Product:

**PEX-AL-PEX Composite Pressure Pipe System**

File No. 475

Issued To :

METZERPLAS  
 KIBBUTZ METZER  
 M.P. HEFER 38820,  
 ISRAEL

IDENTIFICATION:

The pipe shall be marked every 5 feet with the size, designation "PEX-AL-PEX", pressure rating for water and temperature for which the pressure rating is valid, ASTM F1281, the manufacturer's name or trademark and the production code. The pipe shall be marked with the UPC® certification mark.

CHARACTERISTICS:

Crosslinked polyethylene composite pressure pipe with welded aluminum tube, reinforced between the inner and outer layers. For radiant heating applicaitons only. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code.

Manufactured in accordance with the physical requirments of ASTM F1281-2005.

MODELS:

16mm, 20mm, 25mm, 32mm

ADDITIONAL COMPANIES:

ADDITIONAL  
 COMPANY INFO: